

Appendix C. NOAA Data Site Wind Performance Summary Fact Sheets

Cover Sheet

As part of the Massachusetts Technology Collaborative (MTC) Offshore Wind Collaborative Pilot Research Program, we have collected and analyzed available windspeed information from the National Oceanic & Atmospheric Administration (NOAA) National Data Buoy Center (NDBC) (<http://www.ndbc.noaa.gov>). This information was then used to analyze the potential economic and environmental performance of northeast offshore wind energy resources.

There were seventeen data sites analyzed for this project (see map and table below). They represent a subset of the historical NOAA stations, and were chosen based on the number of years of data available. The table below lists station names, ID numbers, locations, and other reference information. It also displays average windspeeds and associated capacity factors for the data sites. The next page gives a detailed description of the content of the individual site fact sheets created for this project.

Locations of the 17 NOAA stations selected for analysis



Source: www.ndbc.noaa.gov/Maps/northeast_hist.shtml

Station Name	Station ID	Location, Latitude Longitude	Distance From Shore, nautical miles (miles)	Location, Direction from Shore Point	Anem. Height, m	Water Depth, m	Ave. Windspeed @ 75m, m/s	Ave. Capacity Factor, %
Logan ¹	14739	42.37 N 71.03 W	0 nm (0 mi)	Logan Airport, Boston, MA	8	-	6.46	25.5
Portland	44007	43.53 N 70.14 W	10 nm (12 mi)	SE of Portland, ME	5	20	7.16	34.9
Isle of Shoals	IOSN3	42.97 N 70.62 W	8 nm (9 mi)	SE of Portsmouth, NH	32	-	7.58	38.2
Boston	44013	42.35 N 70.69 W	20 nm (23 mi)	East of Boston, MA	5	60	7.60	37.9
Jonesport	44027	44.27 N 67.31 W	20 nm (23 mi)	SE of Jonesport, ME	5	180	7.88	40.3
Georges Bank	44011	41.11 N 66.62 W	170 nm (196 mi)	East of Hyannis, MA	5	90	8.03	41.1
Delaware Bay	44009	38.46 N 74.70 W	30 nm (35 mi)	SE of Cape May, NJ	5	30	8.15	42.7
Long Island	44025	40.25 N 73.17 W	30 nm (35 mi)	South of Islip, NY	5	40	8.26	43.7
Nantucket	44008	40.50 N 69.43 W	50 nm (58 mi)	SE of Nantucket, MA	5	60	8.34	43.7
Gulf of Maine	44005	43.18 N 69.18 W	80 nm (92 mi)	East of Portsmouth, NH	5	20	8.36	44.3
Ambrose Light	ALSN6	40.46 N 73.83 W	20 nm (23 mi)	SE of Ambrose Light, NY	29	-	8.38	44.9
SE Cape Cod	44018	41.26 N 69.29 W	30 nm (35 mi)	East of Nantucket, MA	5	70	8.39	43.6
Buzzard's Bay	BUZM3	41.40 N 71.03 W	30 nm (35 mi)	SW of Buzzard's Bay, MA	25	-	8.40	45.1
Matinicus Rock	MISM1	43.78 N 68.86 W	4 nm (5 mi)	SE of Matinicus Island, ME	33	-	8.47	45.0
Montauk Point	44017	40.70 N 72.00 W	20 nm (23 mi)	SW of Montauk Point, NY	5	50	8.61	46.4
Mt. Desert Rock	MDRM1	43.97 N 68.13 W	20 nm (23 mi)	SE of Mt. Desert Island, ME	32	-	8.63	46.3
Hotel	44004	38.47 N 70.56 W	200 nm (230 mi)	East of Cape May, NJ	5	3,120	8.98	49.5

Source: NOAA NDBC and NCDC¹ Station Pages

¹ Logan Airport data come from the NOAA National Climatic Data Center (NCDC) (<http://www.ncdc.noaa.gov>).


The research team analyzed historical NOAA windspeed data to calculate windspeeds at wind turbine hub height for each individual data site, and to estimate potential generation, revenue, and avoided emissions from locating wind turbines in similar environments. These calculations are based on historical *hourly* values of NOAA windspeeds, New England Independent System Operator (ISO-NE) wholesale power prices, and Environmental Protection Agency (EPA) emission rates for fossil generators. After finishing the analysis, we created fact sheets to display key results and to address the potential economic and environmental performance of the wind resource at the data sites.

As the individual fact sheets show, inter-annual and intra-annual variability in windspeeds and power generation is quite large. These variations in the wind resource must be taken into account when assessing the performance of prospective wind farms.

Below is a description of the various sections of the individual data site fact sheets.

Average Annual Windspeed @ 75m and Average Seasonal Windspeed @ 75m

Windspeeds were averaged from hourly wind data measured at anemometer height and scaled to 75m hub height using the Log Law (with .2mm roughness length). Anemometer heights at the data sites vary from 5 to 33 meters. Hub height was chosen as representative of likely U.S. offshore configurations. Log Law (and .2mm roughness length) was chosen as the best conservative estimate of the wind scaling relationship.



Annual Capacity Factor and Seasonal Capacity Factor and Annual Capacity Factor Percent Changes - from Average and from Previous Year


Capacity factor is defined as estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours of a given time period.

Annual Generation per Installed Megawatt and Seasonal Generation per Installed Megawatt

Electrical energy was estimated from hourly windspeeds using the power curve for the GE 3.6s turbine with 111m diameter, and then summed to annual or seasonal values.

Annual Revenue from Sales of Electricity per Installed Megawatt

Revenue was calculated using estimated generation and historical ISO-NE hourly wholesale power prices. The graph also shows average historical power prices.



Intra-Annual Variability of Windspeed @ 75m and Variability of Seasonal Windspeed @ 75m

The box plots show statistics of hourly windspeed data for each year and season.

The table at the bottom of the fact sheets shows annual values for the main parameters, plus unit revenue, as well as avoided emissions per installed MW. Avoided emissions were calculated from estimated generation and hourly marginal emissions rates, which were derived from EPA Acid Rain / Ozone Transport Commission (OTC) Program Hourly Emissions Data.

These fourteen facts sheets² show selected results for individual data sites. For more information, and for comparisons across sites, please refer to the main Report and the previous Appendices. The following Fact Sheets appear in alphabetical order.

These fact sheets, as well as the main Report and Appendices, are available via <http://lfee.mit.edu/>.

² The three data sites Jonesport, SE Cape Cod, and Montauk Point are excluded from these calculations as they only have several years of data,

Station: Ambrose Light, NY

Location: 40.5 N, 73.8 W


Depth: 0 m (0 ft)

Distance from Shore: 20 nm (23 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 8.72 Ave: 8.38
Min: 7.93 StdDev: 0.23


Averaged from hourly wind data measured at 29m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 48.1 Ave: 44.9
Min: 41.0 StdDev: 2.0


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 4.21 Ave: 3.94
Min: 3.59 StdDev: 5.00


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)

Max: 203.0 Ave: 123.0
Min: 77.0 StdDev: 46.0

Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)


$\Delta\%$ - $\Delta\%$ -
Ave. Prev. Year

Max: 7.1 15.1

Min: -8.8 -8.9

Ave: - 0.1

StdDev: 4.5 6.7




Intra-Annual Variability of Windspeed @ 75m (m/s)

Max: 38.66
Min: 0.00
Ave: 8.38


Box plots show statistics of hourly windspeed data for each year

Max
75th per.
Median
25th per.
Min




Station: Ambrose Light, NY

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)

Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values




Variability of Seasonal Windspeed @ 75m (m/s)

Max: 38.66
Min: 0.00
Ave: 8.38

Box plots show statistics of hourly windspeed data for each season

Max
75th per.
Median
25th per.
Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (000\$/MW)	Unit Revenue (\$/kWh)	Cap Fac Δ% - Ave.	Cap Fac Δ% - Prev. Year	Avoided Emissions per Installed Megawatt				
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)
1985												
1986												
1987												
1988												
1989												
1990												
1991	8.19	3.82	43.6			-2.9	-4.0					
1992	8.24	3.79	43.1			-1.3	2.9					
1993	8.35	3.88	44.3	78.0	2.0	0.2	1.5					
1994	8.40	3.94	45.0	77.0	2.0							
1995	8.48	4.04	46.1	85.0	2.1	2.7	2.5					
1996	8.72	4.07	46.4	95.0	2.3	3.2	0.5					
1997	8.60	4.19	47.8	106.0	2.5	6.4	3.1					
1998	8.40	3.91	44.7	78.0	2.0	-0.5	-6.5	16.7	4.3	4.9	1.3	3,267
1999	8.70	4.21	48.1	109.0	2.6	7.1	7.7	15.8	3.7	4.5	1.1	3,366
2000	8.41	3.95	45.0	158.0	4.0	0.1	-6.5	11.3	2.9	3.5	0.9	2,941
2001	7.93	3.59	41.0	138.0	3.9	-8.8	-8.9	9.2	2.6	3.0	0.8	749
2002	8.58	4.13	47.1	142.0	3.4	5.0	15.1	8.9	2.2	3.1	0.8	2,652
2003	8.24	3.82	43.6	203.0	5.3	-2.9	-7.5					739
2004	8.13	3.78	43.0	202.0	5.3	-4.2	-1.3					767
Max:	8.72	4.21	48.1	203.0	5.3	7.1	15.1					
Min:	7.93	3.59	41.0	77.0	2.0	-8.8	-8.9					
Ave:	8.38	3.94	44.9	123.0	3.1	-	0.1					
StdDev:	0.23	5.00	2.0	46.0	1.3	4.5	6.7					


Station: Boston

Location: 42.4 N, 70.7 W
Depth: 60 m (197 ft)
Distance from Shore: 20 nm (23 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 8.29 Ave: 7.60
Min: 7.00 StdDev: 0.41


Averaged from hourly wind data measured at 5m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 44.8 Ave: 37.9
Min: 32.7 StdDev: 3.5


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 3.94 Ave: 3.32
Min: 2.86 StdDev: 11.0


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)


Max: 177.0 Ave: 102.0
Min: 58.0 StdDev: 43.0

Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)

$\Delta\%$ - $\Delta\%$ -
Ave. Prev. Year
Max: 18.3 24.7
Min: -13.6 -16.0
Ave: - 0.8
StdDev: 9.2 10.7




Intra-Annual Variability of Windspeed @ 75m (m/s)

Max: 32.57
Min: 0.00
Ave: 7.60


Box plots show statistics of hourly windspeed data for each year

Max
75th per.
Median
25th per.
Min




Station: Boston

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)

Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values




Variability of Seasonal Windspeed @ 75m (m/s)

Max: 32.57
Min: 0.00
Ave: 7.60

Box plots show statistics of hourly Max windspeed data for each season

75th per.
Median
25th per.
Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (000\$/MW)	Unit Revenue (\$/kWh)	Cap Fac % - Ave.	Cap Fac % - Prev. Year	Avoided Emissions per Installed Megawatt				
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)
1985	7.16	3.04	34.8			-8.2	-11.5					
1986	7.00	2.93	33.5			-	-3.6					
1987	7.35	3.15	35.9			-5.1	7.2					
1988	8.23	3.94	44.8			18.3	24.7					
1989	8.03	3.61	41.2			8.8	-8.0					
1990	7.90	3.59	41.0			8.2	-0.6					
1991	8.29	3.76	43.0			13.4	4.8					
1992	8.22	3.70	42.2			11.4	-1.8					
1993	8.04	3.60	41.1	73.0	2.0	8.5	-2.6					
1994	7.57	3.29	37.6	65.0	2.0	-0.8	-8.6					
1995	7.31	3.08	35.1	66.0	2.1	-7.3	-6.5					
1996	7.41	3.15	35.9	75.0	2.4	-5.3	2.2					
1997	7.69	3.38	38.5	88.0	2.6	1.8	7.4					
1998	7.07	2.92	33.3	58.0	2.0	-12.0	-13.5	12.5	4.3	3.7	1.3	2,431
1999	7.33	3.15	36.0	73.0	2.3	-4.9	8.0	11.8	3.7	3.4	1.1	2,529
2000	7.74	3.42	38.9	142.0	4.2	2.8	8.1	9.7	2.9	3.0	0.9	2,524
2001	7.09	2.87	32.7	114.0	4.0	-13.6	-16.0	7.4	2.6	2.4	0.9	2,114
2002	7.82	3.47	39.6	122.0	3.5	4.6	21.2	7.6	2.2	2.7	0.8	738
2003	7.40	3.13	35.7	173.0	5.5	-5.7	-9.9					2,665
2004	7.40	3.21	36.6	177.0	5.5	-3.4	2.5					768
Max:	8.29	3.94	44.8	177.0	5.5	18.3	24.7					
Min:	7.00	2.86	32.7	58.0	2.0	-13.6	-16.0					
Ave:	7.60	3.32	37.9	102.0	3.2	-	0.8					
StdDev:	0.41	11.00	3.5	43.0	1.3	9.2	10.7					


Station: Buzzards Bay

Location: 41.4 N, 71.0 W
Depth: 0 m (0 ft)
Distance from Shore: 30 nm (35 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 8.83 Ave: 8.40
Min: 7.73 StdDev: 0.28


Averaged from hourly wind data measured at 25m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 48.8 Ave: 45.1
Min: 38.6 StdDev: 2.7


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 4.28 Ave: 3.96
Min: 3.39 StdDev: 7.00


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)


Max: 213.0 Ave: 126.0
Min: 73.0 StdDev: 53.0

Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)

$\Delta\%$ - $\Delta\%$ -
Ave. Prev. Year
Max: 8.2 19.9
Min: -14.5 -9.7
Ave: - 0.7
StdDev: 6.1 8.1




Intra-Annual Variability of Windspeed @ 75m (m/s)

Max: 37.76
Min: 0.00
Ave: 8.40


Box plots show statistics of hourly windspeed data for each year

Max
75th per.
Median
25th per.
Min




Station: Buzzards Bay

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)

Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values




Variability of Seasonal Windspeed @ 75m (m/s)

Max: 37.76
Min: 0.00
Ave: 8.40

Box plots show statistics of hourly windspeed data for each season

Max
75th per.
Median
25th per.
Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (000\$/MW)	Unit Revenue (\$/kWh)	Cap Fac % - Ave.	Cap Fac % - Prev. Year	Avoided Emissions per Installed Megawatt				
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)
1985	8.00	3.68	42.0			-7.0						
1986	8.36	3.96	45.2			0.3	7.8					
1987	8.64	4.27	48.6			7.7	7.4					
1988	8.53	4.05	46.3			2.6	-4.8					
1989												
1990	8.70	4.27	48.8			8.1	5.4					
1991	8.58	4.12	47.1			4.3	-3.5					
1992	8.37	3.88	44.2			-2.1	-6.2					
1993	8.58	4.08	46.6	83.0	2.0	3.3	5.6					
1994	8.13	3.69	42.1	73.0	2.0	-6.7	-9.7					
1995	8.04	3.64	41.6	77.0	2.1	-7.9	-1.3					
1996	7.73	3.39	38.6	80.0	2.4	-14.5	-7.1					
1997	8.55	4.06	46.3	105.0	2.6	2.6	19.9					
1998	8.33	3.85	44.0	77.0	2.0	-2.5	-5.0	16.3	4.2	4.8	1.3	3,199
1999	8.57	4.07	46.5	108.0	2.7	3.1	5.8	15.2	3.7	4.4	1.1	3,256
2000	8.69	4.14	47.1	176.0	4.3	4.4	1.2	11.9	2.9	3.7	0.9	3,075
2001	8.15	3.79	43.2	155.0	4.1	-4.2	-8.2	9.7	2.6	3.2	0.8	748
2002	8.83	4.28	48.8	152.0	3.6	8.2	12.9	9.3	2.2	3.3	0.8	2,800
2003	8.51	4.00	45.6	213.0	5.3	1.1	-6.5					767
2004	8.34	3.93	44.7	212.0	5.4	-0.8	-1.9					
Max:	8.83	4.28	48.8	213.0	5.4	8.2	19.9					
Min:	7.73	3.39	38.6	73.0	2.0	-14.5	-9.7					
Ave:	8.40	3.96	45.1	126.0	3.2	-	0.7					
StdDev:	0.28	7.00	2.7	53.0	1.3	6.1	8.1					


Station: *Delaware Bay*

Location: 38.5 N, 74.7 W
 Depth: 30 m (98 ft)
 Distance from Shore: 30 nm (35 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 8.75 Ave: 8.15
 Min: 7.61 StdDev: 0.35


Averaged from hourly wind data measured at 5m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 47.2 Ave: 42.7
 Min: 37.8 StdDev: 3.2


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 4.14 Ave: 3.74
 Min: 3.31 StdDev: 8.00


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)

Max: 211.0 Ave: 119.0
 Min: 66.0 StdDev: 52.0

Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)


$\Delta\%$ - $\Delta\%$ -
 Ave. Prev. Year

Max: 10.6 19.6

Min: -11.5 -17.5

Ave: - 0.4

StdDev: 7.4 11.6



Intra-Annual Variability of Windspeed @ 75m (m/s)


Max: 33.79

Min: 0.00

Ave: 8.15


Box plots show statistics of hourly windspeed data for each year

Max
 75th per.
 Median
 25th per.
 Min




Station: Delaware Bay

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)

Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values




Variability of Seasonal Windspeed @ 75m (m/s)

Max: 33.79
Min: 0.00
Ave: 8.15

Box plots show statistics of hourly windspeed data for each season

Max
75th per.
Median
25th per.
Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (000\$/MW)	Unit Revenue (\$/kWh)	Cap Fac Δ% - Ave.	Cap Fac Δ% - Prev. Year	Avoided Emissions per Installed Megawatt				
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)
1985												
1986												
1987												
1988												
1989												
1990												
1991	8.48	3.99	45.5			6.6	9.9	3.1				
1992	8.75	4.12	46.9			9.9	-17.5					
1993	7.85	3.39	38.7	68.0	2.0	9.4						
1994	7.67	3.40	38.8	68.0	2.0	9.2	0.2					
1995	7.97	3.68	42.0	78.0	2.1	-1.6	8.4					
1996	7.88	3.56	40.5	85.0	2.4	-5.2	-3.7					
1997	8.25	3.83	43.7	99.0	2.6	2.2	7.8					
1998	7.61	3.31	37.8	66.0	2.0	-11.5	-13.5	14.2	4.3	4.1	1.3	2,756
1999	8.38	3.96	45.2	100.0	2.5	5.8	19.6	14.7	3.7	4.2	1.1	3,150
2000	8.35	3.95	44.9	169.0	4.3	5.2	-0.6	11.2	2.9	3.5	0.9	2,924
2001	7.84	3.51	40.0	141.0	4.0	-6.3	-11.0	9.0	2.6	3.0	0.8	737
2002	8.59	4.14	47.2	146.0	3.5	10.6	18.0	8.9	2.2	3.2	0.8	2,582
2003	8.14	3.70	42.3	200.0	5.4	-1.0	-10.5					765
2004	8.29	3.89	44.3	211.0	5.4	3.7	4.7					
Max:	8.75	4.14	47.2	211.0	5.4	10.6	19.6					
Min:	7.61	3.31	37.8	66.0	2.0	-11.5	-17.5					
Ave:	8.15	3.74	42.7	119.0	3.2	-	0.4					
StdDev:	0.35	8.00	3.2	52.0	1.3	7.4	11.6					


Station: Georges Bank

Location: 41.1 N, 66.6 W
Depth: 90 m (295 ft)
Distance from Shore: 170 nm (196 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 8.72 Ave: 8.03
Min: 7.09 StdDev: 0.47

Averaged from hourly wind data measured at 5m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 47.2 Ave: 41.1
Min: 34.2 StdDev: 3.6


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 4.14 Ave: 3.60
Min: 3.00 StdDev: 11.0


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)


Max: 206.0 Ave: 120.0
Min: 69.0 StdDev: 51.0

Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)


$\Delta\%$ - $\Delta\%$ -
Ave. Prev. Year
Max: 14.8 22.7
Min: -16.8 -15.2
Ave: - 1.2
StdDev: 8.8 10.3



Intra-Annual Variability of Windspeed @ 75m (m/s)


Max: 34.47
Min: 0.00
Ave: 8.03

Box plots show statistics of hourly windspeed data for each year
Max
75th per.
Median
25th per.
Min




Station: Georges Bank

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values



Variability of Seasonal Windspeed @ 75m (m/s)

Max: 34.43
Min: 0.00
Ave: 8.03

Box plots show statistics of hourly Max windspeed data 75th per. for each season
Median
25th per.
Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (000\$/MW)	Unit Revenue (\$/kWh)	Cap Fac % - Ave.	Cap Fac % - Prev. Year	Avoided Emissions per Installed Megawatt				
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)
1985	7.47	3.27	37.3			-9.2	2.3					
1986	7.61	3.35	38.2			-7.1						
1987	7.30	3.10	35.4			-13.8	-7.2					
1988	7.09	3.00	34.2			-16.8	-3.5					
1989	7.40	3.12	35.7			-13.3	4.3					
1990	8.14	3.83	43.7			6.4	22.7					
1991	8.13	3.71	42.4				3.1	-3.1				
1992	8.31	3.73	42.5				3.3	0.2				
1993	8.17	3.62	41.3	73.0	2.0	0.4	-2.8					
1994	7.92	3.55	40.6	70.0	2.0	-1.3	-1.7					
1995	8.63	4.14	47.2	88.0	2.1	14.8	16.4					
1996	7.94	3.52	40.0	84.0	2.4	-2.7	-15.2					
1997	8.72	4.05	46.2	105.0	2.6	12.4	15.4					
1998	7.72	3.44	39.3	69.0	2.0	-4.4	-14.9	14.8	4.3	4.3	1.3	2,875
1999	8.31	3.75	42.8	91.0	2.4	4.2	8.9	14.2	3.8	4.1	1.1	3,020
2000	8.60	3.97	45.2	168.0	4.2	10.0	5.6	11.4	2.9	3.6	0.9	748
2001	7.94	3.54	40.4	149.0	4.2	-1.8	-10.7	9.2	2.6	3.1	0.9	739
2002	8.41	3.90	44.6	137.0	3.5	8.4	10.3	8.5	2.2	3.0	0.8	2,614
2003	8.41	3.73	42.6	205.0	5.5	3.5	-4.5					767
2004	8.35	3.75	42.7	206.0	5.5	3.9	0.4					
Max:	8.72	4.14	47.2	206.0	5.5	14.8	22.7					
Min:	7.09	3.00	34.2	69.0	2.0	-16.8	-15.2					
Ave:	8.03	3.60	41.1	120.0	3.2	-	1.2					
StdDev:	0.47	11.00	3.6	51.0	1.3	8.8	10.3					


Station: Gulf of Maine

Location: 43.2 N, 69.2 W
Depth: 20 m (66 ft)
Distance from Shore: 170 nm (196 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 8.95 Ave: 8.36
Min: 7.41 StdDev: 0.47


Averaged from hourly wind data measured at 5m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 48.7 Ave: 44.3
Min: 37.2 StdDev: 3.6


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 4.28 Ave: 3.89
Min: 3.26 StdDev: 10.0


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)

Max: 226.0 Ave: 128.0
Min: 75.0 StdDev: 54.0

Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)


$\Delta\%$ - $\Delta\%$ -
Ave. Prev. Year
Max: 9.8 21.5
Min: -16.1 -19.5
Ave: - 1.7
StdDev: 8.1 9.7



Intra-Annual Variability of Windspeed @ 75m (m/s)


Max: 33.64
Min: 0.00
Ave: 8.36

Box plots show statistics of hourly windspeed data for each year
Max
75th per.
Median
25th per.
Min




Station: Gulf of Maine

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)

Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values




Variability of Seasonal Windspeed @ 75m (m/s)

Max: 33.64

Min: 0.00

Ave: 8.36

Box plots show statistics of hourly Max windspeed data 75th per. for each season Median 25th per. Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (000\$/MW)	Unit Revenue (\$/kWh)	Cap Fac % - Ave.	Cap Fac % - Prev. Year	Avoided Emissions per Installed Megawatt				
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)
1985	7.41	3.26	37.2			-16.1	8.5					
1986	7.74	3.54	40.4			-8.9	-1.2					
1987	7.77	3.49	39.9			-10.1	2.9					
1988	7.90	3.60	41.0			-7.5	-2.0					
1989	7.82	3.52	40.2			-9.4						
1990	8.63	4.14	47.3			6.7	17.7					
1991	8.24	3.73	42.6			-3.9	-9.9					
1992	8.69	4.10	46.7			5.4	9.7					
1993	8.83	4.13	47.1	83.0	2.0	6.3	0.9					
1994	8.82	4.20	48.0	83.0	2.0	8.3	1.8					
1995	8.43	3.94	45.0	84.0	2.1	1.4	-6.3					
1996	8.60	3.99	45.4	95.0	2.4	2.4	1.0					
1997	8.72	4.16	47.5	107.0	2.6	7.1	4.6					
1998	8.11	3.76	42.9	75.0	2.0	-3.2	-9.6	16.0	4.3	4.7	1.3	3,126
1999	8.66	4.12	47.0	99.0	2.4	6.0	9.5	15.5	3.8	4.4	1.1	832
2000	8.95	4.28	48.7	177.0	4.1	9.8	3.6	12.2	2.9	3.8	0.9	3,175
2001	7.76	3.43	39.2	136.0	4.0	-11.6	-19.5	8.8	2.6	2.9	0.9	746
2002	8.79	4.17	47.6	147.0	3.5	7.4	21.5	9.1	2.2	3.2	0.8	2,533
2003	8.59	3.98	45.4	218.0	5.5	2.5	-4.6					738
2004	8.67	4.18	47.6	226.0	5.4	7.4	4.8					769
Max:	8.95	4.28	48.7	226.0	5.5	9.8	21.5					
Min:	7.41	3.26	37.2	75.0	2.0	-16.1	-19.5					
Ave:	8.36	3.89	44.3	128.0	3.2	-	1.7					
StdDev:	0.47	10.00	3.6	54.0	1.3	8.1	9.7					


Station: Hotel

Location: 38.5 N, 70.6 W
Depth: 3,120 m (10,234 ft)
Distance from Shore: 200 nm (230 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 10.44 Ave: 8.98
Min: 8.32 StdDev: 0.50


Averaged from hourly wind data measured at 5m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 61.7 Ave: 49.5
Min: 43.6 StdDev: 4.1


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 5.40 Ave: 4.34
Min: 3.82 StdDev: 0.36


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)

Max: 247.0 Ave: 142.0
Min: 79.0 StdDev: 61.0

Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)


$\Delta\%$ - $\Delta\%$ -
Ave. Prev. Year

Max: 24.6 13.4

Min: -11.9 -23.0

Ave: - -0.7

StdDev: 8.2 8.6




Intra-Annual Variability of Windspeed @ 75m (m/s)

Max: 40.24
Min: 0.00
Ave: 8.98


Box plots show statistics of hourly windspeed data for each year

Max
75th per.
Median
25th per.
Min




Station: Hotel

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)

Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values




Variability of Seasonal Windspeed @ 75m (m/s)

Max: 40.24
Min: 0.00
Ave: 8.98

Box plots show statistics of hourly windspeed data for each season

Max
75th per.
Median
25th per.
Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (000\$/MW)	Unit Revenue (\$/kWh)	Cap Fac % - Ave.	Cap Fac % - Prev. Year	Avoided Emissions per Installed Megawatt					
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)	CO2 (kg/MWh)
1985	10.44	5.40	61.7			24.6	-						
1986	8.66	4.16	47.5			-4.0	-23.0						
1987	8.32	3.89	44.5			-10.2	-6.4						
1988	8.55	4.17	47.4			-4.2	6.7						
1989	8.91	4.33	49.5			-0.1	4.3						
1990	8.34	3.82	43.6			-11.9	-11.8						
1991	8.52	3.95	45.1			-9.0	3.3						
1992	8.86	4.22	48.1			-2.9	6.7						
1993	8.84	4.18	47.7	84.0	2.0	-3.7	-0.8						
1994	9.13	4.50	51.3	88.5	2.0	3.7	7.6						
1995	9.38	4.66	53.2	99.6	2.1	7.5	3.7						
1996	8.77	4.21	47.9	100.0	2.4	-3.2	-9.9						
1997	8.97	4.26	48.6	109.9	2.6	-1.8	1.4						
1998	8.40	3.95	45.1	78.7	2.0	-8.8	-7.1	16.7	4.2	4.9	1.2	3,293	833
1999	9.09	4.48	51.2	111.4	2.5	3.4	13.4	16.9	3.8	4.8	1.1	3,593	801
2000	9.54	4.64	52.8	196.8	4.2	6.7	3.1	13.3	2.9	4.1	0.9	3,446	747
2001	9.18	4.54	51.8	191.1	4.2	4.7	-1.8	11.8	2.6	3.9	0.8	3,346	737
2002	9.08	4.38	50.0	154.8	3.5	1.0	-3.5	9.5	2.2	3.4	0.8	3,353	765
2003	9.41	4.65	53.1	247.3	5.3	7.2	6.1						
2004	9.24	4.39	50.0	236.8	5.4	1.0	-5.8						
Max:	10.44	5.40	61.7	247.0	5.4	24.6	13.4						
Min:	8.32	3.82	43.6	79.0	2.0	-11.9	-23.0						
Ave:	8.98	4.34	49.5	142.0	3.2	-	-0.7						
StdDev:	0.50	0.36	4.1	61.0	1.3	8.2	8.6						


Station: Isle of Shoals, NH

Location: 43.0 N, 70.6 W
Depth: 0 m (0 ft)
Distance from Shore: 8 nm (9 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 8.12 Ave: 7.58
Min: 7.00 StdDev: 0.24


Averaged from hourly wind data measured at 32m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 43.6 Ave: 38.2
Min: 32.4 StdDev: 2.3


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 3.82 Ave: 3.35
Min: 2.84 StdDev: 7.00


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)

Max: 189.0 Ave: 109.0
Min: 66.0 StdDev: 46.0

Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)


$\Delta\%$ - $\Delta\%$ -
Ave. Prev. Year

Max: 14.1 16.8

Min: -15.3 -12.6

Ave: - 0.6

StdDev: 6.1 7.7



Intra-Annual Variability of Windspeed @ 75m (m/s)


Max: 30.72

Min: 0.00

Ave: 7.58


Box plots show statistics of hourly windspeed data for each year

Max
75th per.
Median
25th per.
Min




Station: Isle of Shoals, NH

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)

Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values




Variability of Seasonal Windspeed @ 75m (m/s)

Max: 30.72
Min: 0.00
Ave: 7.58

Box plots show statistics of hourly 75m windspeed data for each season

Max
75th per.
Median
25th per.
Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (000\$/MW)	Unit Revenue (\$/kWh)	Cap Fac % - Ave.	Cap Fac % - Prev. Year	Avoided Emissions per Installed Megawatt				
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)
1985	7.45	3.28	37.4			-2.1	-10.3					
1986	7.10	3.00	34.3			-10.3	-8.4					
1987	7.00	2.84	32.4			-15.3	-5.5					
1988	7.48	3.32	37.8			-1.1	16.8					
1989	7.66	3.43	39.2			2.6	3.7					
1990	7.77	3.55	40.5			6.1	3.4					
1991	7.64	3.34	38.1			-0.3	-6.0					
1992	7.61	3.40	38.7			1.3	1.6					
1993	7.63	3.35	38.2	67.0	2.0	0.1	-1.2					
1994	7.66	3.35	38.3	66.0	2.0	0.2	0.1					
1995	7.42	3.19	36.4	68.0	2.1	-4.8	-5.0					
1996	7.50	3.23	36.8	76.0	2.4	-3.6	1.2					
1997	7.80	3.53	40.3	91.0	2.6	5.5	9.4					
1998	7.51	3.29	37.6	66.0	2.0	-1.7	-6.8	14.0	4.2	4.1	1.3	2,737
1999	7.67	3.46	39.5	88.0	2.5	3.4	5.1	12.8	3.7	3.7	1.1	801
2000	7.74	3.48	39.6	142.0	4.1	3.7	0.3	10.0	2.9	3.1	0.9	2,585
2001	7.59	3.31	37.8	136.0	4.1	-1.1	-4.6	8.4	2.5	2.8	0.8	748
2002	8.12	3.82	43.6	133.0	3.5	14.1	15.3	8.3	2.2	2.9	0.8	2,447
2003	7.61	3.34	38.1	181.0	5.4	-0.3	-12.6					739
2004	7.66	3.48	39.6	189.0	5.4	3.7	4.0					2,932
Max:	8.12	3.82	43.6	189.0	5.4	14.1	16.8					768
Min:	7.00	2.84	32.4	66.0	2.0	-15.3	-12.6					
Ave:	7.58	3.35	38.2	109.0	3.2	-	0.6					
StdDev:	0.24	7.00	2.3	46.0	1.3	6.1	7.7					

Station: Logan

Location: 42.4 N, 71.0 W


Depth: 0 m (0 ft)

Distance from Shore: 0 nm (0 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 7.30 Ave: 6.46
Min: 5.99 StdDev: 0.38


Averaged from hourly wind data measured at 8m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 33.8 Ave: 25.5
Min: 20.8 StdDev: 3.4


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 2.96 Ave: 2.24
Min: 1.82 StdDev: 16.0


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)


Max: 113.0 Ave: 68.0
Min: 39.0 StdDev: 25.0

Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)

$\Delta\%$ - $\Delta\%$ -
Ave. Prev. Year
Max: 32.3 15.9
Min: -18.5 -20.4
Ave: - -2.1
StdDev: 13.3 11.2




Intra-Annual Variability of Windspeed @ 75m (m/s)

Max: 29.27
Min: 0.17
Ave: 6.46


Box plots show statistics of hourly windspeed data for each year

Max
75th per.
Median
25th per.
Min




Station: Logan

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)

Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values




Variability of Seasonal Windspeed @ 75m (m/s)

Max: 29.27
Min: 0.17
Ave: 6.46

Box plots show statistics of hourly windspeed data for each season

Max 75th per.
Median
25th per.
Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (000\$/MW)	Unit Revenue (\$/kWh)	Cap Fac % - Ave.	Cap Fac % - Prev. Year	Avoided Emissions per Installed Megawatt				
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)
1985												
1986												
1987												
1988												
1989												
1990	7.30	2.96	33.8			32.3	11.5	-15.8				
1991	6.80	2.49	28.5			3.3	-7.3					
1992	6.57	2.32	26.4			2.6	-0.9					
1993	6.56	2.29	26.1	47.0	2.0	2.4	4.9					
1994	6.68	2.40	27.4	47.0	2.0	7.4						
1995	7.09	2.66	30.4	57.0	2.2	18.9	10.7					
1996	6.29	2.12	24.2	50.0	2.4	-5.3	-20.4					
1997	6.35	2.16	24.7	56.0	2.6	-3.3	2.1					
1998	6.11	1.94	22.2	39.0	2.0	-13.1	-10.1	8.2	4.2	2.4	1.3	1,612
1999	6.24	2.08	23.8	56.0	2.7	-6.9	7.1	7.7	3.7	2.2	1.1	829
2000	6.40	2.21	25.2	93.0	4.2	-1.3	6.1	6.4	2.9	2.0	0.9	1,651
2001	5.99	1.82	20.8	79.0	4.3	-18.5	-17.4	4.6	2.5	1.5	0.8	752
2002	6.32	2.11	24.1	75.0	3.6	-5.6	15.9	4.5	2.1	1.6	0.8	1,337
2003	6.04	1.96	22.3	109.0	5.6	-12.6	-7.4					733
2004	6.19	2.04	23.2	113.0	5.5	-9.2	3.9					764
Max:	7.30	2.96	33.8	113.0	5.6	32.3	15.9					
Min:	5.99	1.82	20.8	39.0	2.0	-18.5	-20.4					
Ave:	6.46	2.24	25.5	68.0	3.3	-	-2.1					
StdDev:	0.38	16.00	3.4	25.0	1.4	13.3	11.2					


Station: Long Island

Location: 40.3 N, 73.2 W
Depth: 40 m (131 ft)
Distance from Shore: 30 nm (35 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 8.71 Ave: 8.26
Min: 7.86 StdDev: 0.27

Averaged from hourly wind data measured at 5m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 47.5 Ave: 43.7
Min: 40.3 StdDev: 2.4


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 4.16 Ave: 3.83
Min: 3.53 StdDev: 6.00


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)

Max: 212.0 Ave: 123.0
Min: 71.0 StdDev: 51.0


Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)

$\Delta\%$ - $\Delta\%$ -
Ave. Prev. Year

Max: 8.7 16.0
Min: -7.7 -15.1
Ave: - 1.0
StdDev: 5.4 8.6




Intra-Annual Variability of Windspeed @ 75m (m/s)

Max: 28.90
Min: 0.00
Ave: 8.26


Box plots show statistics of hourly windspeed data for each year

Max
75th per.
Median
25th per.
Min




Station: Long Island

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)

Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values




Variability of Seasonal Windspeed @ 75m (m/s)

Max: 28.90
Min: 0.00
Ave: 8.26

Box plots show statistics of hourly windspeed data for each season

Max
75th per.
Median
25th per.
Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (000\$/MW)	Unit Revenue (\$/kWh)	Cap Fac Δ% - Ave.	Cap Fac Δ% - Prev. Year	Avoided Emissions per Installed Megawatt				
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)
1985												
1986												
1987												
1988												
1989												
1990												
1991	7.86	3.56	40.6			-7.0	1.0					
1992	7.95	3.60	41.0			-6.1						
1993	8.18	3.76	42.9	76.0	2.0	-1.8	4.6					
1994	8.35	3.90	44.5	77.0	2.0	1.9	3.7					
1995	8.27	3.88	44.3	82.0	2.1	1.3	-0.6					
1996	8.22	3.76	42.8	90.0	2.4	-2.0	-3.3					
1997	8.71	4.16	47.5	108.0	2.6	8.7	11.0					
1998	7.90	3.53	40.3	71.0	2.0	-7.7	-15.1	15.1	4.3	4.4	1.3	2,943
1999	8.35	3.93	44.8	97.0	2.5	2.6	11.2	14.7	3.7	4.2	1.1	3,139
2000	8.49	3.98	45.3	165.0	4.2	3.7	1.1	11.3	2.9	3.5	0.9	744
2001	7.96	3.57	40.7	143.0	4.0	-6.9	-10.2	9.2	2.6	3.0	0.9	738
2002	8.62	4.13	47.2	145.0	3.5	8.0	16.0	9.0	2.2	3.2	0.8	2,629
2003	8.42	3.96	45.2	212.0	5.4	3.5	-4.2					3,170
2004	8.33	3.90	44.4	212.0	5.4	1.7	-1.7					767
Max:	8.71	4.16	47.5	212.0	5.4	8.7	16.0					
Min:	7.86	3.53	40.3	71.0	2.0	-7.7	-15.1					
Ave:	8.26	3.83	43.7	123.0	3.2	-	1.0					
StdDev:	0.27	6.00	2.4	51.0	1.3	5.4	8.6					


Station: Matinicus Rock, ME

Location: 43.8 N, 68.9 W
Depth: 0 m (0 ft)
Distance from Shore: 4 nm (5 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 8.79 Ave: 8.47
Min: 8.07 StdDev: 0.21


Averaged from hourly wind data measured at 33m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 48.0 Ave: 45.0
Min: 42.2 StdDev: 1.9


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 4.20 Ave: 3.95
Min: 3.70 StdDev: 4.00


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)

Max: 221.0 Ave: 126.0
Min: 80.0 StdDev: 50.0

Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)

$\Delta\%$ - $\Delta\%$ -
Ave. Prev. Year
Max: 6.6 12.8
Min: -6.2 -11.9
Ave: - 0.6
StdDev: 4.1 6.8




Intra-Annual Variability of Windspeed @ 75m (m/s)

Max: 34.43
Min: 0.00
Ave: 8.47


Box plots show statistics of hourly windspeed data for each year

Max
75th per.
Median
25th per.
Min




Station: Matinicus Rock, ME

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)

Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values




Variability of Seasonal Windspeed @ 75m (m/s)

Max: 34.43
Min: 0.00
Ave: 8.47

Box plots show statistics of hourly windspeed data for each season

Max
75th per.
Median
25th per.
Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (000\$/MW)	Unit Revenue (\$/kWh)	Cap Fac % - Ave.	Cap Fac % - Prev. Year	Avoided Emissions per Installed Megawatt				
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)
1985	8.26	3.82	43.6			-3.1						
1986	8.07	3.70	42.2			-6.2	-3.2					
1987	8.50	3.93	44.8			-0.4	6.2					
1988	8.52	4.00	45.5			1.2	1.6					
1989	8.26	3.78	43.1			-4.2	-5.3					
1990	8.54	4.04	46.1			2.4	6.8					
1991	8.67	4.07	46.5			3.3	1.0					
1992	8.21	3.71	42.3			-6.1	-9.1					
1993	8.58	3.97	45.4	80.0	2.0	0.8	7.3					
1994	8.68	4.11	46.9	81.0	2.0	4.2	3.4					
1995	8.26	3.79	43.3	81.0	2.1	-3.9	-7.7					
1996	8.53	3.94	44.9	93.0	2.4	-0.3	3.7					
1997	8.59	4.08	46.6	106.0	2.6	3.6	3.9					
1998	8.64	4.09	46.7	82.0	2.0	3.8	0.2	17.4	4.2	5.1	1.3	3,403
1999	8.69	4.11	46.9	104.0	2.5	4.1	0.3	15.3	3.7	4.4	1.1	800
2000	8.70	4.04	46.0	169.0	4.2	2.2	-1.9	11.6	2.9	3.6	0.9	2,998
2001	8.15	3.73	42.6	148.0	4.0	-5.5	-7.5	9.6	2.6	3.2	0.9	746
2002	8.79	4.20	48.0	149.0	3.5	6.6	12.8	9.2	2.2	3.2	0.8	2,753
2003	8.27	3.70	42.3	200.0	5.4	-6.1	-11.9					739
2004	8.55	4.09	46.6	221.0	5.4	3.5	10.2					767
Max:	8.79	4.20	48.0	221.0	5.4	6.6	12.8					
Min:	8.07	3.70	42.2	80.0	2.0	-6.2	-11.9					
Ave:	8.47	3.95	45.0	126.0	3.2	-	0.6					
StdDev:	0.21	4.00	1.9	50.0	1.3	4.1	6.8					

Station: Mt. Desert Rock, ME

Location: 44.0 N, 68.1 W


Depth: 0 m (0 ft)

Distance from Shore: 20 nm (23 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 9.12 Ave: 8.63
Min: 8.25 StdDev: 0.23


Averaged from hourly wind data measured at 32m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 50.7 Ave: 46.3
Min: 43.3 StdDev: 2.0


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 4.44 Ave: 4.06
Min: 3.80 StdDev: 5.00


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)


Max: 234.0 Ave: 131.0
Min: 80.0 StdDev: 55.0

Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)

$\Delta\%$ - $\Delta\%$ -
Ave. Prev. Year
Max: 9.5 9.1
Min: -6.4 -10.5
Ave: - 0.7
StdDev: 4.3 5.8




Intra-Annual Variability of Windspeed @ 75m (m/s)

Max: 32.37
Min: 0.00
Ave: 8.63


Box plots show statistics of hourly windspeed data for each year

Max
75th per.
Median
25th per.
Min




Station: Mt. Desert Rock, ME

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)

Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values




Variability of Seasonal Windspeed @ 75m (m/s)

Max: 32.37
Min: 0.00
Ave: 8.63

Box plots show statistics of hourly 75th per. Max windspeed data for each season

Median
25th per.
Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (000\$/MWh)	Unit Revenue (\$/kWh)	Cap Fac Δ% - Ave.	Cap Fac Δ% - Prev. Year	Avoided Emissions per Installed Megawatt				
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)
1985	8.36	3.88	44.3			-4.4	2.1					
1986	8.39	3.96	45.2			-2.3						
1987	8.33	3.82	43.6			-5.8	-3.6					
1988	8.65	4.13	47.0			1.7	7.9					
1989	8.49	3.96	45.2			-2.2	-3.8					
1990	8.58	4.03	46.0			-0.6	1.7					
1991	8.55	4.01	45.7			-1.2	-0.6					
1992	8.34	3.82	43.5			-6.1	-4.9					
1993	8.61	3.99	45.5	80.0	2.0	-1.6	4.8					
1994	8.85	4.21	48.1	83.0	2.0	3.9	5.5					
1995	8.25	3.80	43.3	81.0	2.1	-6.4	-9.8					
1996	8.60	4.01	45.7	95.0	2.4	-1.3	5.4					
1997	8.80	4.15	47.4	108.0	2.6	2.5	3.8					
1998	8.63	4.10	46.8	82.0	2.0	1.1	-1.4	17.4	4.2	5.1	1.3	3,405
1999	8.90	4.25	48.5	107.0	2.5	4.8	3.7	16.0	3.8	4.6	1.1	802
2000	8.95	4.22	48.1	178.0	4.2	3.9	-0.8	12.2	2.9	3.8	0.9	3,134
2001	8.57	4.07	46.4	160.0	3.9	0.4	-3.4	10.4	2.6	3.5	0.9	739
2002	9.12	4.44	50.7	157.0	3.5	9.5	9.1	9.6	2.2	3.4	0.8	3,007
2003	8.70	3.97	45.3	213.0	5.4	-2.1	-10.5					767
2004	8.90	4.32	49.2	234.0	5.4	6.4	8.6					
Max:	9.12	4.44	50.7	234.0	5.4	9.5	9.1					
Min:	8.25	3.80	43.3	80.0	2.0	-6.4	-10.5					
Ave:	8.63	4.06	46.3	131.0	3.2	-	0.7					
StdDev:	0.23	5.00	2.0	55.0	1.3	4.3	5.8					


Station: Nantucket

Location: 40.5 N, 69.4 W
Depth: 60 m (197 ft)
Distance from Shore: 50 nm (58 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 9.12 Ave: 8.34
Min: 7.25 StdDev: 0.57

Averaged from hourly wind data measured at 5m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 50.2 Ave: 43.7
Min: 35.1 StdDev: 4.4


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 4.39 Ave: 3.83
Min: 3.09 StdDev: 0.38


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)

Max: 217.0 Ave: 119.0
Min: 69.0 StdDev: 52.0

Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)

$\Delta\%$ - $\Delta\%$ -
Ave. Prev. Year

Max: 14.8 16.2

Min: -19.6 -17.3

Ave: - 1.1

StdDev: 10 8.9



Intra-Annual Variability of Windspeed @ 75m (m/s)


Max: 34.60

Min: 0.00

Ave: 8.34


Box plots show statistics of hourly windspeed data for each year

Max
75th per.
Median
25th per.
Min




Station: Nantucket

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)

Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values




Variability of Seasonal Windspeed @ 75m (m/s)

Max: 34.60
Min: 0.00
Ave: 8.34

Box plots show statistics of hourly windspeed data for each season

Max
75th per.
Median
25th per.
Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (000\$/MW)	Unit Revenue (\$/kWh)	Cap Fac % - Ave.	Cap Fac % - Prev. Year	Avoided Emissions per Installed Megawatt				
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)
1985	7.32	3.21	36.7			-16.0	10.1					
1986	7.85	3.54	40.4			-7.5						
1987	8.52	3.85	44.0			0.7	8.9					
1988	9.04	4.39	50.0			14.4	13.6					
1989	9.12	4.39	50.2			14.8	0.4					
1990	9.02	4.34	49.6			13.5	-1.1					
1991	8.87	4.18	47.8			9.3	-3.7					
1992	9.12	4.27	48.6			11.3	1.8					
1993	8.80	4.06	46.3	82.0	2.0	6.0	-4.7					
1994	8.23	3.71	42.4	73.0	2.0	-3.0	-8.5					
1995	8.01	3.72	42.5	79.0	2.1	-2.7	0.3					
1996	7.25	3.09	35.1	74.0	2.4	-19.6	-17.3					
1997	7.87	3.44	39.3	90.0	2.6	-10.0	11.9					
1998	7.74	3.47	39.6	69.0	2.0	-9.4	0.7	14.7	4.2	4.3	1.3	2,886
1999	8.33	3.83	43.7	96.0	2.5	0.0	10.3	14.4	3.8	4.1	1.1	3,067
2000	8.39	3.85	43.8	161.0	4.2	0.3	0.3	11.1	2.9	3.4	0.9	2,851
2001	7.91	3.50	39.9	142.0	4.1	-8.5	-8.8	9.1	2.6	3.0	0.9	2,582
2002	8.64	4.07	46.4	143.0	3.5	6.3	16.2	8.8	2.2	3.1	0.8	738
2003	8.64	3.99	45.6	217.0	5.4	4.4	-1.8					3,113
2004	8.18	3.68	41.8	202.0	5.5	-4.2	-8.2					765
Max:	9.12	4.39	50.2	217.0	5.5	14.8	16.2					
Min:	7.25	3.09	35.1	69.0	2.0	-19.6	-17.3					
Ave:	8.34	3.83	43.7	119.0	3.2	-	1.1					
StdDev:	0.57	0.38	4.4	52.0	1.3	10.0	8.9					


Station: Portland

Location: 43.5 N, 70.1 W
Depth: 20 m (66 ft)
Distance from Shore: 10 nm (12 mi)

Average Annual Windspeed @ 75m (m/s)

Max: 7.97 Ave: 7.16
Min: 6.45 StdDev: 0.41


Averaged from hourly wind data measured at 5m and scaled to hub height of 75m using Log Law (.2mm roughness length)



Annual Capacity Factor (%)

Max: 40.6 Ave: 34.9
Min: 28.6 StdDev: 3.5


Annual estimated generation expressed as a percentage of maximum output from installed capacity operating for all hours in a given period



Annual Generation per Installed Megawatt (GWh/MWi)

Max: 3.57 Ave: 3.06
Min: 2.50 StdDev: 12.0


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter



Annual Revenue from Sales of Electricity per Installed Megawatt (000\$/MWi)


Max: 161.0 Ave: 92.0
Min: 54.0 StdDev: 39.0

Calculated using estimated generation and historical ISO-NE hourly energy prices



Annual Capacity Factor Percent Changes - from Average and from Previous Year (%)


$\Delta\%$ - $\Delta\%$ -
Ave. Prev. Year
Max: 16.6 31.4
Min: -18.1 -15.0
Ave: - 0.5
StdDev: 9.9 11.2



Intra-Annual Variability of Windspeed @ 75m (m/s)


Max: 30.93
Min: 0.00
Ave: 7.16

Box plots show statistics of hourly windspeed data for each year
Max
75th per.
Median
25th per.
Min




Station: Portland

Average Seasonal Windspeed @ 75m (m/s)




Seasonal Capacity Factor (%)

These two plots show monthly values and average seasonal values for windspeed and capacity factor



Seasonal Generation per Installed Megawatt (GWh/MW)


Electrical energy estimated from hourly windspeeds using power curve for GE 3.6s turbine with 111m diameter, then summed to seasonal values



Variability of Seasonal Windspeed @ 75m (m/s)

Max: 30.93
Min: 0.00
Ave: 7.16

Box plots show statistics of hourly Max windspeed data 75th per. for each season
Median
25th per.
Min



Year	Ave. Ann. Windspeed @ 75m (m/s)	Ann. Gen (GWh/MW)	Ann. Capacity Factor (%)	Ann. Revenue (\$000/MW)	Unit Revenue (\$/kWh)	Cap Fac % - Ave.	Cap Fac % - Prev. Year	Avoided Emissions per Installed Megawatt				
								SO2 (tonne)	SO2 (kg/MWh)	NOx (tonne)	NOx (kg/MWh)	CO2 (tonne)
1985	7.06	3.00	34.3			-1.6	-2.3					
1986	6.96	2.93	33.5			-3.9						
1987	7.29	3.16	36.1			3.6	7.9					
1988	7.54	3.43	39.1			12.1	8.2					
1989	7.23	3.15	35.9			3.1	-8.1					
1990	7.70	3.47	39.6			13.6	10.3					
1991	7.79	3.46	39.5			13.4	-0.2					
1992	7.97	3.57	40.6			16.6	2.8					
1993	7.67	3.31	37.8	67.0	2.0	8.5	-6.9					
1994	7.03	2.90	33.1	57.0	2.0	-5.0	-12.4					
1995	6.45	2.50	28.6	54.0	2.1	-18.1	-13.8					
1996	6.69	2.67	30.4	63.0	2.4	-12.9	6.3					
1997	6.99	2.96	33.8	77.0	2.6	-3.1	11.3					
1998	7.04	2.97	33.9	60.0	2.0	-2.7	0.3	12.6	4.2	3.7	1.3	2,471
1999	6.97	2.96	33.8	70.0	2.4	-3.1	-0.4	11.1	3.7	3.2	1.1	2,377
2000	7.02	2.97	33.9	121.0	4.1	-2.9	0.2	8.5	2.9	2.6	0.9	745
2001	6.53	2.52	28.8	100.0	4.0	-17.5	-15.0	6.4	2.6	2.1	0.9	1,861
2002	7.45	3.31	37.8	116.0	3.5	8.4	31.4	7.2	2.2	2.6	0.8	738
2003	6.91	2.88	32.8	159.0	5.5	-5.8	-13.1					2,535
2004	6.98	2.98	33.9	161.0	5.4	-2.8	3.2					766
Max:	7.97	3.57	40.6	161.0	5.5	16.6	31.4					
Min:	6.45	2.50	28.6	54.0	2.0	-18.1	-15.0					
Ave:	7.16	3.06	34.9	92.0	3.2	-	0.5					
StdDev:	0.41	12.00	3.5	39.0	1.3	9.9	11.2					